



Pressure Test Certification Affidavit

In accordance with the Florida Building Code, 2020, seventh edition, 454.2.12.1; all pool piping shall be tested and proved tight to the satisfaction of the administrative authority, under static or air pressure test, of not less than, thirty-five (35) P.S.I. for fifteen (15) minutes. This affidavit is to certify that this portion of the code is in compliance.

Test Data Required

Start Date _____

Start Time: _____

End Date _____

End Time: _____

Beginning Pressure: _____

End Pressure _____

Company Name: _____ Telephone: _____

Address: _____ Permit Number: _____

Contractor Signature: _____

Contractor's Printed Name: _____

Date: _____

Exemption: Circulating pumps need not be tested as required in this section.